



July 13, 2018

Mr. Mitchell Mahler
Rodenhouse Fastening Systems
974 Front NW Suite 100
Grand Rapids, MI 49504

RE: Fastener Evaluation

Dear Mitchell:

We have reviewed the test data on the Rodenhouse Plasti-Grip PBLP2 washers and find the washers to be acceptable alternates to those noted in the various Dryvit specifications where mechanical fasteners are required. Those systems include: Outsulation[®], Outsulation RMD, and Outsulation LCMD.

The use of the Rodenhouse Plasti-Grip PBLP2 washers to secure the insulation board to the substrate will not affect the issuance of a warranty for the corresponding Dryvit Outsulation system being installed.

Should you have any questions, please do not hesitate to contact our office.

Very truly yours,

A handwritten signature in black ink that reads "Bill Preston".

William M. Preston
Senior Engineer/Code Specialist

cc: Rodenhouse File